

B Sampson Trading

2 Burley Road, Langham, Oakham, Rutland, LE15 7HY, UK.

Tel No; 01572 759651 mobile 07850 377112

Email; bsampson.trading@gmail.com web;

VAT No; 120 2956 44

Ref; 535

Oakham Town Council
Rol House,
Long Row,
Oakham,
Rutland LE15 6LN
Tel 01572 723627.

25 October 2023

Proforma Invoice 535

In respect of ;

Solar Water heating System on Public Facility at Church St Car Park

On visual on inspection, the solar water heating system appears in good condition except for lack of pressure in the water circuit and one tube on the roof is damaged. As the system was installed in 2009; 14 years ago, it is likely that the pumps are not in good condition. The water circuit can be recharged, but the pumps would have to be tested independently. Even if the pumps work, their work life could not be guaranteed. I would recommend that they are replaced with new pumps.

The options are;

1 Inspect and recharge the system test run.	
Cost £250.00 plus VAT £50	Total £300.00

2. As above in No 1. Plus supply 2 x new pumps at £100.00	
Cost £300.00 plus 2 pumps £100.	
Therefore £400 plus VAT £80	Total £480.00

3. As above in No 2, supply and fit new tube to the solar panel £100.00	
Cost £400.00 plus the tube £100.00.	
Therefore £500.00 plus VAT £100	Total £600.00

I have listed the options as I see them. Unless there is anything unforeseen in the roof space, Option 3 would reestablish the system to as new condition
I hope this is of interest

Regards
Brian Sampson